Proje	ect: <u>Battery Park City Ballfield and</u> <u>Community Center Resiliency</u> – <u>General Contractor Services</u>	Date:	February 24, 2020
		RE: # of Pages:	Addendum # 10 1
Author Reque Resilie	llowing response (the "Response") is provided rity ("BPCA") by the close of business on Fest for Proposals (the "RFP") for the Battery Fency Project – General Contractor Services. The mediately following the question.	bruary 18, 2020, Park City Ballfiel	in connection with its d and Community Center
1.	We are bidding this Project, as we are looking for vendors, we came to know that vendors are looking for synthetic turf details and their make. We went through all drawings and specs there is no details regarding synthetic turf. Kindly send us specs for synthetic turf or give us a link where we can download specs for the same.		
	Due to warranty considerations, all turf repairs, to the extent required, are to be performed directly by BPCA, which will utilize its turf contractor Athletic Fields of America (the matter of financial responsibility for avoidable damage to the turf is addressed in Addendum #4 to the RFP).		
	As a further clarification of and revision to the Project Scope of Work, the selected Proposer will NOT be responsible for performing the removal, relocation, and/or restoration of any part of the turf. Rather, the selected Proposer must protect any and all areas of the turf within the Project site using two layers of ¾" (minimum) plywood. Also, any heavy equipment may not be left on any area of the turf for any period in excess of forty-eight (48) consecutive hours. Essential equipment is to be left on the turf only while in necessary use.		
receive	ning the line below, I am acknowledging that ed, reviewed, and understood, and will be inc ent must be attached to the Proposal for cons	corporated into th	

Signature

Date

Distributed to: All prospective Proposers

Number of pages received: \_\_\_\_\_<fill in>

Print Name